

**THE PRESSURE SYSTEMS SAFETY REGULATIONS 2000 SI 128
THE PRESSURE SYSTEMS SAFETY REGULATIONS (NI) 2004 No. 222**

REPORT OF EXAMINATION OF SYSTEM OR PARTS THEREOF

Policy: H9S086179

Plant Code: B08A12

Previous Report: 270412-009-0018LS2

Site: 00001


Schedule: B0001

Report Number: 020513-008-0020SH3

PS1
WRITTEN SCHEME NUMBER: WS01

1. Name and address of owner	THE GALLEON LEISURE CENTRE 99 Titchfield Street, Kilmarnock East Ayrshire, KA1 1QY
2. Subject to written agreement under the relevant Schedule of the regulations	No
3. Location of systems and name of user if different from above	Compressor Room
4. (a) System identification (b) Identification of part of system (c) Description of part of system	PS01 Whole Air Receiver Pressure Gauge & Safety Valve - Horizontal Welded CIS Vergato Serial No.:- 450
5. Results of examination and condition of parts examined in accordance with Written Scheme of Examination	Working Examination Only Slight thinning on lower surfaces but remains suitable for further service.
6. Repairs (if any) required in order to prevent imminent danger if none enter "None"	None
7. Defects (other than those specified at 6 above) which require attention if none enter "None"	None
8. (a) Safe operating limit (b) Change in safe operating limits and date by which required if none enter "None"	9 bar None
Change in written scheme if required if none enter "None"	None
10. Postponement (Section 9(7))* Name of Competent Person Name of Users Representative Date of Postponement Date of limit of Postponement * If none enter "None"	None
11. Other observations	The Receiver should be drained of condensate at regular intervals. Minimum thickness recorded at previous thorough examination: 2.65mm.

Certification :- I certify that the above system or parts thereof was examined in accordance with the Written Scheme of Examination and that the above is a true report of the result.

Inspecting Engineer: Mr. R. Chambers
Qualification: Engineer Surveyor
Signature: 

	Thorough	Working
Date of Examination:	---	22 Apr 2013
Date of Last Examination:	26 Apr 2012	26 Apr 2012
Date of Next Examination:	26 Jun 2014	22 May 2014

TO BE INSERTED IN THE GENERAL REGISTER

HSB Engineering Insurance Services Limited
Registered office: Cairo House, Greenacres Road, Waterhead, Oldham, Lancashire OL4 3JA
t 0845 345 5510 f 0845 345 5610 w www.hsbeil.com
Registered in England and Wales: 03010292 VAT Registration No. GB 652 6422 43

