



**RODOL LIMITED**

*Industrial Water and Effluent Treatment*

## Certificate of Result of a Clean and Disinfection.

GALLEON CENTRE  
99 TITCHFIELD STREET  
KILMARNOCK  
KA1 1QY

Ref: G/RD/66  
Certificate Date: 18/10/16  
Clean & Disinfection Date: 28/08/16

FOR THE ATTENTION OF MR. D. HASSON

Plant: EVAPORATIVE CONDENSER

### Clean & Disinfection Result: Satisfactory

Method: Rodolite H (hypochlorite based solution) added and circulated to ensure distribution throughout the system.

Total Contact Time: 1 hour

Analytical:

Final Free Chlorine Reserve: Over 50 p.p.m.

Representative: MR. I. BLACK

Phone No: 07720 775412

AUTHORISED SIGNATORY  
FOR  
RODOL LIMITED

RODOL LTD. (Tech Dept.) Richmond Row. Liverpool L3 3BP.