

# REPORT OF EXAMINATION OF HOT WATER BOILER

Munich RE 



HSB Engineering Insurance

Policy: H4S086179

Plant Code: B01B10

Previous Report: 230315-003-0025SB2

Site: 00001

Schedule: B0008

Report Number: 220316-003-0027PL1

HWB1

1. Name and address of occupier	THE GALLEON LEISURE CENTRE 99 Titchfield Street, Kilmarnock East Ayrshire, KA1 1QY
2. Description, type and distinctive number(s) of boiler	Hot Water Heating Boiler De Dietrich Serial No.:- 31174 Plant No.:- BOILER 1
3. Date of construction  The history should be briefly given, and the examiner should state whether he has seen the last previous report	1986  Installed new at this location  Previous report seen
4. Date of last hydraulic test (if any), and pressure applied	1986 200 psi
5. Parts inaccessible	All internal surfaces
6. Nature and type of examination	Thorough visual and functional examination
Condition	External :-  Internal :-  Surfaces in jackets :- (if any)
	No apparent defects  Not accessible  Not applicable
8. Are fittings correct type? Are fittings all in satisfactory condition?	Yes Yes
9. Type and condition of fuel emergency shut off valve	Internal in gas supply
10. Maximum permissible working pressure	114 psi Safety valve: 15 psi
11. Repairs (if any) required and period within which they should be executed and any other conditions which the person making the examination thinks it necessary to specify for securing safe working	None
Other observations	Working at 2.4 bar. Safety valve should be tested/serviced on a regular basis. Location: Plant Room. <b>CHECKED BY JOHNSTONE</b> <b>CONTROLS 15/1/16</b> JK

I certify that on the date of examination, the above mentioned boiler was examined as indicated and that the above is a true report of the result.

Date of Examination: 10 Mar 2016

Date of Last Examination: 12 Mar 2015

Inspecting Engineer: Mr. R. Chambers

Date of Next Examination: 10 Mar 2017

Signature: 

Qualification: Engineer Surveyor

# REPORT OF EXAMINATION OF HOT WATER BOILER



HSB Engineering Insurance

Policy: H4S086179

Plant Code: B01B10

Previous Report: 230315-004-0025SB2

Site: 00001

Schedule: B0009

Report Number: 220316-004-0027PL1

HWB1

1. Name and address of occupier	THE GALLEON LEISURE CENTRE 99 Titchfield Street, Kilmarnock East Ayrshire, KA1 1QY
2. Description, type and distinctive number(s) of boiler	Hot Water Heating Boiler De Dietrich Serial No.:- 31175 Plant No.:- BOILER 2
3. Date of construction  The history should be briefly given, and the examiner should state whether he has seen the last previous report	1986  Installed new at this location.  Previous report seen
4. Date of last hydraulic test (if any), and pressure applied	1986 ---
5. Parts inaccessible	All internal surfaces
6. Nature and type of examination	Thorough visual and functional examination
Condition	
External :-	No apparent defects
Internal :-	Not accessible
Surfaces in jackets :- (if any)	Not applicable
8. Are fittings correct type? Are fittings all in satisfactory condition?	Yes Yes
9. Type and condition of fuel emergency shut off valve	Internal in gas supply
10. Maximum permissible working pressure	114 psi Safety valve: 3.10 bar
11. Repairs (if any) required and period within which they should be executed and any other conditions which the person making the examination thinks it necessary to specify for securing safe working	None
Other observations	Working at 2.4 bar. Safety valve passing at working pressure - to repair. Safety valve should be tested/serviced on a regular basis. Location: Plant Room <b>CHECKED BY JOHNSTONE CONTROLS</b> <b>ON 15/1/16 (repair to be arranged)</b>

I certify that on the date of examination, the above mentioned boiler was examined as indicated and that the above is a true report of the result.

Date of Examination: 10 Mar 2016

Date of Last Examination: 12 Mar 2015

Inspecting Engineer: Mr. R. Chambers

Date of Next Examination: 10 Mar 2017

Signature:

Qualification: Engineer Surveyor



# REPORT OF EXAMINATION OF HOT WATER BOILER

Munich RE 



HSB Engineering Insurance

Policy: H4S086179

Plant Code: B01B10

Previous Report: 230315-005-0025SB2

Site: 00001

Schedule: B0007

Report Number: 220316-005-0027PL1

HWB1

1. Name and address of occupier	THE GALLEON LEISURE CENTRE 99 Titchfield Street, Kilmarnock East Ayrshire, KA1 1QY
2. Description, type and distinctive number(s) of boiler	Hot Water Heating Boiler De Dietrich Serial No.:- 31173 Plant No.:- BOILER 3
3. Date of construction  The history should be briefly given, and the examiner should state whether he has seen the last previous report	1986  Installed new at this location.  Previous report seen
4. Date of last hydraulic test (if any), and pressure applied	1986 200 psi
5. Parts inaccessible	All internal surfaces
6. Nature and type of examination	Thorough visual and functional examination
Condition	
External :-	No apparent defects
Internal :-	Not accessible
Surfaces in jackets :- (if any)	Not applicable
8. Are fittings correct type? Are fittings all in satisfactory condition?	Yes Yes
9. Type and condition of fuel emergency shut off valve	Internal in gas supply
10. Maximum permissible working pressure	114 psi Safety valve: 3.10 bar
11. Repairs (if any) required and period within which they should be executed and any other conditions which the person making the examination thinks it necessary to specify for securing safe working	None
12. Other observations	Working at 2.4 bar. Safety valve should be tested/serviced on a regular basis. Location: Plant Room. <b>CHECKED BY JOHNSTONE</b> <b>CONTROLS 15/1/16</b> JK

I certify that on the date of examination, the above mentioned boiler was examined as indicated and that the above is a true report of the result.

Date of Examination: 10 Mar 2016

Date of Last Examination: 12 Mar 2015

Inspecting Engineer: Mr. R. Chambers

Date of Next Examination: 10 Mar 2017

Signature: 

Qualification: Engineer Surveyor

