

# REPORT OF EXAMINATION OF HOT WATER BOILER

Munich RE 



HSB Engineering Insurance

Policy: H9S086179

Plant Code: B01B10

Previous Report: 230315-001-0025SB2

Site: 00001

Schedule: B0017

Report Number: 220316-001-0027PL1

HWB1

1. Name and address of occupier	THE GALLEON LEISURE CENTRE 99 Titchfield Street, Kilmarnock East Ayrshire, KA1 1QY
2. Description, type and distinctive number(s) of boiler	Hot Water Heating Boiler Gas-Fired (Vertical) Boss Serial No. :- 085003720601003
3. Date of construction  The history should be briefly given, and the examiner should state whether he has seen the last previous report	2009  Installed new at this location  Previous report seen
4. Date of last hydraulic test (if any), and pressure applied	Unknown
5. Parts inaccessible	All fireside and waterside parts
6. Nature and type of examination	Thorough visual and functional examination
Condition	
External :-	No apparent defects
Internal :-	Inaccessible
Surfaces in jackets :- (if any)	Not applicable
8. Are fittings correct type? Are fittings all in satisfactory condition?	Yes Yes
9. Type and condition of fuel emergency shut off valve	Internal gas supply
10. Maximum permissible working pressure	150 psi
11. Repairs (if any) required and period within which they should be executed and any other conditions which the person making the examination thinks it necessary to specify for securing safe working	None
Other observations	Safety valve should be tested at intervals specified by manufacturer. Location: Dry Sports, Plant Room <b>CHECKED BY JIMMIE CONRAW 15/1/16</b> JK

I certify that on the date of examination, the above mentioned boiler was examined as indicated and that the above is a true report of the result.

Date of Examination: 10 Mar 2016

Date of Last Examination: 12 Mar 2015

Inspecting Engineer: Mr. R. Chambers

Date of Next Examination: 10 Mar 2017

Signature: 

Qualification: Engineer Surveyor



# REPORT OF EXAMINATION OF HOT WATER BOILER

Munich RE 



HSB Engineering Insurance

Policy: H98086179

Plant Code: B01B10

Previous Report: 230315-002-0025SB2

Site: 00001

Schedule: B0023

Report Number: 220316-002-0027PL1

HWB1

1. Name and address of occupier	THE GALLEON LEISURE CENTRE 99 Titchfield Street, Kilmarnock East Ayrshire, KA1 1QY
2. Description, type and distinctive number(s) of boiler	Hot Water Heating Boiler Gas-Fired (Vertical) Andrews Serial No.:- GK140ZE414
3. Date of construction	Not ascertained  Installed new at this location  Previous report seen
4. Date of last hydraulic test (if any), and pressure applied	Unknown
5. Parts inaccessible	All fireside and waterside parts
6. Nature and type of examination	Thorough visual and functional examination
Condition	
External :-	No apparent defects.
Internal :-	Inaccessible
Surfaces in jackets :- (if any)	Not applicable
8. Are fittings correct type? Are fittings all in satisfactory condition?	Yes Yes
9. Type and condition of fuel emergency shut off valve	Internal in gas supply
10. Maximum permissible working pressure	150 psi
11. Repairs (if any) required and period within which they should be executed and any other conditions which the person making the examination thinks it necessary to specify for securing safe working	None
Other observations	Model: 54/418PP. Rated: 120 kW. Safety valve should be tested at intervals specified by manufacturer. Monitor condition of galvanised elbow at inlet connection. Location: Dry Sports, Plant Room <b>CHECKED BY JOHNSTONE</b> <b>CONTROLS 15/1/16</b>


I certify that on the date of examination, the above mentioned boiler was examined as indicated and that the above is a true report of the result.

Date of Examination: 10 Mar 2016

Date of Last Examination: 12 Mar 2015

Inspecting Engineer: Mr. R. Chambers

Date of Next Examination: 10 Mar 2017

Signature: 

Qualification: Engineer Surveyor

